

## Division de la Protection des eaux

L-4361 Esch/Alzette

Rombach/Martelange
7100

## Concentration

		Entrée								Sortie						
Date	Débit (m3/j)	P <sub>tot</sub> (mg/l)	NH <sub>4</sub> (mg/l)	NO <sub>3</sub> (mg/l)	N <sub>tot</sub> (mg/l)	DBO <sub>5</sub> (mg/l)	DCO (mg/l)	MES (mg/l)	Débit (m3/j)	P <sub>tot</sub> (mg/l)	NH <sub>4</sub> (mg/l)	NO <sub>3</sub> (mg/l)	N <sub>tot</sub> (mg/l)	DBO <sub>5</sub> (mg/l)	DCO (mg/l)	MES (mg/l)
21/02/2018	1973	2,2	9,9	14,2	18,0	120,0	226,0	120,0	1973	0,7	6,3	24,8	13,1	15,0	36,0	18,0
04/04/2018	2511	1,3	6,9	4,4	17,0	40,0	110,0	290,0	2511	0,7	0,3	44,3	15,0	4,0	28,0	2,5
16/05/2018	713	5,0	38,7	0,9	35,2	345,0	574,0	342,0	713	1,2	0,3	25,5	7,4	15,0	36,0	6,0
28/08/2018	578	7,5	39,8	0,9	40,1	540,0	1082,0	634,0	578	1,4	0,3	38,9	10,1	7,0	23,0	7,0
05/09/2018	548	3,5	38,2	0,9	33,2	140,0	235,0	105,0	548	1,2	0,3	34,0	8,6	7,0	20,0	2,0
Durchschnitt:	1265	3,9	26,7	4,3	28,7	237,0	445,4	298,2	1265	1,0	1,5	33,5	10,8	9,6	28,6	7,1