

## Division de la Protection des eaux

L-4361 Esch/Alzette

Medernach

5000

## Concentration

		Entrée								Sortie						
Date	Débit (m³/j)	P <sub>tot</sub> (mg/l)	NH <sub>4</sub> (mg/l)	NO <sub>3</sub> (mg/l)	N <sub>Iot</sub> (mg/l)	DBO <sub>5</sub> (mg/l)	DCO (mg/l)	MES (mg/l)	Débit (m³/j)	P <sub>tot</sub> (mg/l)	NH <sub>4</sub> (mg/l)	NO <sub>3</sub> (mg/l)	N <sub>Iot</sub> (mg/l)	DBO <sub>5</sub> (mg/l)	DCO (mg/l)	MES (mg/l)
08/02/2018	1934	2,1	10,0	19,6	16,0	115,0	198,0	88,0	1934	1,1	0,3	64,6	15,7	2,0	22,0	19,0
10/04/2018	1921	1,9	15,8	12,4	18,6	165,0	345,0	137,0	1921	1,1	0,3	86,6	20,4	17,0	18,0	8,0
14/06/2018	1913	1,1	11,4	11,4	14,6	76,0	127,0	62,0	1913	1,4	0,3	72,3	17,3	6,0	7,5	7,0
09/08/2018	1439	1,2	11,7	6,1	13,6	178,0	370,0	266,0	1439	1,8	0,3	71,8	17,9	9,0	20,0	8,0
18/09/2018	1333	3,0	22,7	0,9	21,7	180,0	562,0	156,0	1333	2,0	0,3	92,1	21,7	3,0	7,5	9,0
Durchschnitt:	1708	1,9	14,3	10,1	16,9	142,8	320,4	141,8	1708	1,5	0,3	77,5	18,6	7,4	15,0	10,2