

## Division de la Protection des eaux

L-4361 Esch/Alzette

Reisdorf

4300

## Concentration

		Entrée								Sortie						
Date	Débit (m3/j)	P <sub>tot</sub> (mg/l)	NH <sub>4</sub> (mg/l)	NO <sub>3</sub> (mg/l)	N <sub>tot</sub> (mg/l)	DBO <sub>5</sub> (mg/l)	DCO (mg/l)	MES (mg/l)	Débit (m3/j)	P <sub>tot</sub> (mg/l)	NH <sub>4</sub> (mg/l)	NO <sub>3</sub> (mg/l)	N <sub>tot</sub> (mg/l)	DBO <sub>5</sub> (mg/l)	DCO (mg/l)	MES (mg/l)
11/01/2018	1045	2,7	9,4	15,5	17,4	240,0	352,0	263,0	1045	0,6	0,3	37,6	9,7	6,0	7,5	12,0
22/03/2018	571	2,6	26,4	1,6	22,4	210,0	294,0	143,0	571	0,8	0,1	22,3	6,0	9,0	15,0	5,0
05/06/2018	937	1,1	11,9	0,9	12,2	94,0	131,0	44,0	937	1,0	0,5	31,1	8,0	13,0	7,5	2,0
17/07/2018	373	4,3	47,3	0,9	42,1	140,0	584,0	215,0	373	1,4	0,3	19,8	5,4	6,0	7,5	5,0
30/10/2018	936	5,1	44,7	0,9	39,1	290,0	559,0	312,0	936	1,6	0,3	26,6	7,1	3,0	17,0	18,0
Durchschnitt:	772	3,2	27,9	4,0	26,6	194,8	384,0	195,4	772	1,1	0,3	27,5	7,2	7,4	10,9	8,4